



A new rooted tree optimization algorithm for economic dispatch with valve-point effect

Yacine Labbi^{a, b}  , Djilani Ben Attous^a, Hossam A. Gabbar^b, Belkacem Mahdad^c, Aboelsood Zidan^b

Show more 

 Share  Cite

<https://doi.org/10.1016/j.ijepes.2016.01.028> 


[Get rights and content](#) 

Abstract

This work proposes a new optimization method called root tree optimization algorithm (RTO). The robustness and efficiency of the proposed RTO algorithm is validated on a 23 standard benchmark nonlinear functions and compared with well-known methods by addressing the same problem. Simulation results show effectiveness of the proposed RTO algorithm in term of solution quality and convergence characteristics. In order to evaluate the effectiveness of the proposed method, 3-unit, 30 Bus IEEE, 13-unit and 15-units are used as case studies with incremental fuel cost functions. The constraints include ramp rate limits, prohibited operating zones and the valve point effect. These constraints make the economic dispatch (ED) problem a non-convex minimization problem with constraints. Simulation results obtained by the proposed algorithm are compared with the results obtained using other methods available in the literature. Based on the numerical results, the proposed RTO algorithm is able to provide better solutions than other reported techniques in terms of fuel cost and robustness.

Graphical abstract

Roots of plant behavior when they look for water (solution) (The search mechanism in RTO algorithm).



Download : [Download high-res image \(205KB\)](#)

Download : [Download full-size image](#)

Introduction

Economic dispatch (ED) is one of the essential operational planning problems in power engineering [1]. ED aims to schedule the committed generating units' outputs in order to meet the load demand at minimum operating cost while satisfying system constraints [2], [3], [4]. In the past twenty years, many researchers have been used heuristic optimization and conventional mathematical techniques to solve ED problem in power systems [5], [6], [7], [8], [9], [10], [11], [12], [13], [14], [15]. Artificial intelligence started to be oriented to the simulation of nature (e.g., to the way how the human brain functions and the human operations thinking). Consequently, a new branch of artificial intelligence has emerged which studies and designs intelligent implements in order to adapt intelligently with their environment and to show a cognitive behavior. Thus, a decision can be taken through the recuperation of the acquired information. This intelligence considers the human beings as an example of these implements. The arithmetic intelligence includes the evaluating computing, fuzzy computing and the neural computing [16], [17].

By the beginning of ninetieth, researches started to simulate other creatures with limited capacities such as ants, birds, and fishes that show a clever social behavior. In 1990, Dorigo suggested an algorithm of ant colony optimization (ACO) which simulates the ants settlements [18]. In 1995, Kennedy and Eberhart suggested an algorithm of practical swarm optimization (PSO) that depends totally on the simulation of birds swarms [19]. PSO and ACO were a starting point for a new branch of the swarm intelligence (SI). The most important characteristics of these new branches are their dependence on digital treatment as they are not based on mathematical knowledge. They are considered as complex algorithms composed of specific steps with known start and end points which lead to problem solving. Even with the great enhancement of computing capacities, still there are challenging problems. Fortunately, many sensitive research algorithms are developed to find suitable solutions for those problems at a reasonable time. They are developed according to the evolution of physiology and biology. Examples are genetic algorithm (GA) and simulated annealing (SA), these techniques are used to solve many problems widely [20], [21], [22].

This work proposes a new algorithm that is called rooted tree optimization (RTO) as its concept is extracted from the movement of plant roots while looking for the nearest place of water. RTO algorithm mimics the behavior of desert plants where the water resources are lacked. If vegetal/biologists scientists allow, we can say that a desert plant roots smell the places of water (intuitive behavior) around it, where these places present the optimal solution. To determine water places, a group of roots which oriented by a special conducting are used. Therefore, this work attempts to introduce an algorithm (RTO) based on that intuitive behavior which leads to water locations and has an oriented movement while looking for the best solution.

RTO starts its search with a random set of solutions (group of roots). Each population member is evaluated based on a given objective function and assigned with its fitness value. Best candidate solutions are forwarded for the next generation/iteration while others are discarded and compensated by new set of random solutions in each generation. Far solutions from water places are omitted and replaced by new roots oriented randomly (they can be replaced by roots closer to the best root of the previous generation). The stopping criterion is the completion of a maximum number of cycles or generations. At the end of the cycles, the solution with the best fitness will be the desired solution.

The main aim of this study is to present the use of the RTO algorithm to the subject of ED in power systems. Thus, the RTO algorithm has been proposed and applied to solve the ED problem for 3, 6, 13 and 15-units test systems. Furthermore, the valve-point effect, the prohibited operating zones, ramp rate limits constraints, and transmission network losses have been considered. The results obtained with the proposed RTO algorithm were analyzed and compared other with optimization results reported in literature. The

remainder of this paper is organized as follows: Section 2 presents the mathematical formulation of ED problem considering various constraints. RTO concept and its application is explained in Section 3. The parameter settings for the test system to evaluate the performance of RTO and the results are discussed in Sections 4 Applying RTO to the ED problem, 5 Experimental results. The conclusion is drawn in Section 6.

Section snippets

Formulation of ED problem

ED problem is an optimization problem to determine the schedule of real power outputs of generating units subjected to the real power balance with load demand as well as limits on generators' outputs. The

mathematical formulation of the problem can be defined as follows: $\min F = \sum_{i=1}^N F_i(P_i)$ where F_i is the total fuel cost of the generator units, which is defined by: $F_i(P_i) = a_i \times P_i^2 + b_i \times P_i + c_i$ where a_i , b_i and c_i are cost coefficients of generator i and P_i is subject to power balance constraints: $\sum_{i=1}^N P_i - P_D - P_{loss} = 0$

Roots look for water

One root has limited capacity, but a group of roots can find together the best place to get water, and the majority of them are located around this place or around the way that links the plant with the resource of water. To create the algorithm, a hypothetical behavior has been added which is the way how roots decide together to choose their orientation according to the wetness degree where the root head is located. These roots move randomly but when one or more find(s) the wetness; they call...

Applying RTO to the ED problem

In this section the proposed RTO algorithm has been applied to solve the economic dispatch problem. To apply the RTO, the following steps have to be taken.

Step 1: Define the input data.

1. In this step, the input data including the cost coefficients of generators, output power constraints, transmission loss matrix coefficients and loads, maximum number of iterations ($Iter_{max}$), size of the population (candidates), the adjustable parameters, and the difference rates R_n , R_r and R_c ...

Step 2: Generate the initial...

2.

...

Experimental results

In order to verify the feasibility and efficiency of the proposed algorithm, RTO algorithm was applied on two set of case studies. The first set includes a 23 standard benchmark functions. The second set includes four test systems (i.e., 3, 6, 13 and 15-units systems) for solving ED problem considering various constraints. In these examples, the RTO algorithm was implemented in MATLAB using Pentium IV, 3-GHz personal computer with 2GB RAM under Windows XP...

Conclusions

This paper proposed a rooted tree algorithm which mimics a plant roots in looking for water under the ground. Economic dispatch problem with valve-point effects being attempted using RTO algorithm for various test systems to evaluate the performance of the proposed RTO algorithm. The efficiency of the proposed RTO algorithm has been verified and tested through its application on some well-known functions and by comparing its performance with recent published techniques. RTO algorithm provides...

References (47)

A. Mahor *et al.*

[Economic dispatch using particle swarm optimization: a review](#)

Renew Sustain Energy (2009)

J.X.V. Neto *et al.*

[Improved quantum-inspired evolutionary algorithm with diversity information applied to ED problem with prohibited operating zones](#)

Energy Convers Manage (2011)

J.S. Alsumait *et al.*

[Application of PS method to power system valve-point ELD](#)

Electr Power Energy Syst (2007)

Z. Zhisheng

[Quantum-behaved particle swarm optimization algorithm for economic load dispatch of power system](#)

Exp Syst Appl (2010)

A. Bhattacharya *et al.*

[Solving complex economic load dispatch problems using biogeography-based optimization](#)

Exp Syst Appl (2010)

X.S. Yang *et al.*

[Firefly algorithm for solving nonconvex economic dispatch problems with valve loading effect](#)

Appl Soft Comput (2012)

R. Kumar *et al.*

[A hybrid multi-agent based particle swarm optimization algorithm for economic power dispatch](#)

Int J Electr Power Energy Syst (2011)

N. Amjady *et al.*

[Solution of non-convex economic dispatch problem considering valve loading effect by a new modified differential evolution algorithm](#)

Int J Electr Power Energy Syst (2010)

K.T. Chaturvedi *et al.*

[Particle swarm optimization with time varying acceleration coefficients for non-convex economic power dispatch](#)

Int J Elect Power Energy Syst (2009)

D. He *et al.*

A hybrid GA approach based on differential evolution for economic dispatch with valve-point effect

Int J Elect Power Energy Syst (2008)



View more references

Cited by (100)

Orchard Algorithm (OA): A new meta-heuristic algorithm for solving discrete and continuous optimization problems

2023, Mathematics and Computers in Simulation

Show abstract

A new firefly algorithm with improved global exploration and convergence with application to engineering optimization

2022, Decision Analytics Journal

Show abstract

Opposition-mutual learning differential evolution with hybrid mutation strategy for large-scale economic load dispatch problems with valve-point effects and multi-fuel options

2022, Information Sciences

Show abstract

Solution of Economic Dispatch Problem Using Hybrid Multi-Verse Optimizer

2022, Electric Power Systems Research

Show abstract

Trees Social Relations Optimization Algorithm: A new Swarm-Based metaheuristic technique to solve continuous and discrete optimization problems

2022, Mathematics and Computers in Simulation

Show abstract

Solving Nonsmooth and Discontinuous Optimal Power Flow problems via interior-point ℓ_p -penalty approach

2022, Computers and Operations Research

Citation Excerpt :

...The introduction of POZ constraints prevent the units to operate in power output zones that may present shaft bearing vibration. The Valve-Point Loading Effect (VPLE) which characterizes the cost functions of thermal units have also been incorporated in such models (Labbi et al., 2016; Gonçalves et al., 2019; Pinheiro et al., 2019a; Pan et al., 2018). The introduction of both VPLE and POZ constraints considerably complicates the solution of ED models....

[Show abstract](#) [View all citing articles on Scopus](#)

Recommended articles (6)

Research article

[A modified artificial bee colony based on chaos theory for solving non-convex emission/economic dispatch](#)

Energy Conversion and Management, Volume 79, 2014, pp. 344-354

[Show abstract](#) 

Research article

[A novel modified hybrid PSO-GSA based on fuzzy logic for non-convex economic dispatch problem with valve-point effect](#)

International Journal of Electrical Power & Energy Systems, Volume 64, 2015, pp. 121-135

[Show abstract](#) 

Research article

[An intelligent \$\theta\$ -Modified Bat Algorithm to solve the non-convex economic dispatch problem considering practical constraints](#)

International Journal of Electrical Power & Energy Systems, Volume 82, 2016, pp. 189-196

[Show abstract](#) 

Research article

[Economic dispatch using chaotic bat algorithm](#)

Energy, Volume 96, 2016, pp. 666-675

[Show abstract](#) 

Research article

[Teaching learning based optimization for economic load dispatch problem considering valve point loading effect](#)

International Journal of Electrical Power & Energy Systems, Volume 73, 2015, pp. 456-464

[Show abstract](#) 

Research article

[KGMO: A swarm optimization algorithm based on the kinetic energy of gas molecules](#)

Information Sciences, Volume 275, 2014, pp. 127-144

[Show abstract](#) 

[View full text](#)



Copyright © 2023 Elsevier B.V. or its licensors or contributors.
ScienceDirect® is a registered trademark of Elsevier B.V.

